



### CHANGES TO FLAME TEST STANDARDS, BS4066 AND IEC60332

There have been several changes to these standards resulting in the publication of new standards BS EN 60332 and BS EN 50266 which supersedes the various parts of BS4066. Some of these have also been replaced by BS EN 60332 specifications. The equivalent IEC60332 standards are shown for reference.

Original Standard Number	Superseded by	Equivalent IEC60332 Part
BS4066 Part 1	BS EN 60332-1-2	IEC60332-1-2
BS4066 Part 2	BS EN 50265-1 in conjunction with:- BS EN 60332-1-2 BS EN 60332-2-2	IEC60332-1-1 IEC60332-2-1 IEC60332-1-2 IEC60332-2-2
BS4066 Part 3 Category A	BS EN 50266-2.2	IEC60332-3-22
BS4066 Part 3 Category B	BS EN 50266-2.3	IEC60332-3-23
BS4066 Part 3 Category C	BS EN 50266-2.4	IEC60332-3-24